



5572 ALHAMBRA AVENUE,
LOS ANGELES, CA 90032
PH (323) 223 3882 FX (323) 223 7941
www.caldyn.com

JOB NAME:
OCH PHARMACY DISTRIBUTION SHELL

CLIENT NAME:
BAY CITY ELECTRIC WORKS

DATE: PRP. BY.: CALDYNN JOB #:
SS

"CALL US - TO SET THINGS RIGHT"

EQUIPMENT TAG: GENSET PACKAGE

SEISMIC CALCULATION WORKSHEET

BUILDING CODE
CBC-2019

SEISMIC DESIGN

$S_{ds} = 0.485$

$I_p = 1$

$a_p = 1$

$R_p = 2.5$

$\Omega_o = 2.0$

BLDG. ELEVATION

EQUIP. LOCATION


$h = 100$ ft

$h = 100$ ft

$R_p = 2.5$

$\Omega_o = 2.0$

a_p, R_p, Ω_o per ASCE 7-16



LOAD COMBINATION
LRFD
(0.9 DL + 1.00 E)

F_p calculated as per ASCE 7-16 (chapter 13)

$$F_p = \frac{0.4 S_{ds} W_p}{\left(\frac{R_p}{I_p} \right) \left(1 + 2 \frac{z}{h} \right)} \quad (13.3-1)$$

F_p is not required to be taken as greater than

$$F_p = 1.0 S_{ds} W_p \quad (13.3-2)$$

$$F_p = 0.35 S_{ds} W_p \quad (13.3-3)$$

where

F_p = seismic design force


S_{ds} = seismic design spectral acceleration at short period, as determined from Section 11.4.4

I_p = component amplification factor that varies from 1.00 to 2.50 (select appropriate value from Table 13.3-1 or 13.3-1)

z = height above ground in feet that varies from 0 to 100 (see Section 13.1.3)

W_p = component operating weight

EQUIPMENT MOUNTING LOCATIONS:



W_p = max. operating weight = 83820 lbs.

L = mounting length = 330 in.

D = mounting width = 135 in.

H_{cg} = Vertical c.o.g. = 56 in.

R = Anchor qty. along length = 7

R = Anchor qty. along width = 2

R = Anchor qty. along width = 14

APPLIED SEISMIC FORCE CALCULATIONS:

$$F_p / W_p = (0.4 \times a_p \times S_{ds} \times (1 + (2 \times (z / h))) / (R_p / I_p)) = 0.08$$

$$F_p / W_p = 0.159 ; F_{pmin} / W_p = 0.3 \times S_{ds} \times I_p = 0.15 ; F_{pmax} / W_p = 1.6 \times S_{ds} \times I_p = 0.78$$

$$F_{ph} = \text{Applied Lateral Seismic Force} = 2.0 \times 0.159 \times W_p = 25146 \text{ lbs. } * \text{WORST CASE}$$

$$F_{pv} = \text{Vertical component of seismic force} = 1.0 \times 0.2 \times S_{ds} \times W_p = 8131 \text{ lbs. } * \text{WORST CASE}$$

CALCULATE PULLOUT LOAD DUE TO OVERTURNING (WORST CASE)

CASE 1: SEISMIC LOAD APPLIED ALONG X-X DIRECTION

$$M_{otx} = \text{Overturning moment} = (F_{ph} \times H_{cg}) + (F_{pv} \times (D / 2)) = 1957019 \text{ lb.-in.}$$

$$M_{rx} = \text{Resisting moment} = (0.9 \times W_p \times (D / 2)) = 5092065 \text{ lb.-in.}$$

$$T_{netx} = \text{Pullout load/ mtg. pt.} = (M_{otx} - M_{rx}) / (R \times D) = -3318 \text{ lbs.}$$

CASE 2: SEISMIC LOAD APPLIED ALONG Y-Y DIRECTION

$$M_{oty} = \text{Overturning moment} = (F_{ph} \times H_{cg}) + (F_{pv} \times (L / 2)) = 2749791 \text{ lb.-in.}$$

$$M_{ry} = \text{Resisting moment} = (0.9 \times W_p \times (L / 2)) = 12447270 \text{ lb.-in.}$$

$$T_{nety} = \text{Pullout load/ mtg. pt.} = (M_{oty} - M_{ry}) / (Q \times L) = -14694 \text{ lbs.}$$

$$T_{net} = -3318 \text{ lbs. } < < < \text{--- Tension demand } T_{anch} = 1.0 \times T_{net} = 0 \text{ lbs.}$$

CALCULATE SHEAR LOAD (WORST CASE)

$$V_{net} = \text{Shear load/ anchor} = F_{ph} / N = 1797 \text{ lbs. } \quad V_{anch} = 1.0 \times V_{net} = 1797 \text{ lbs.}$$

ANCHORAGE REQUIREMENTS (PER ICC ESR-3814):

(14) 7/8"Ø HILTI HIT RE 500 V3 HAS R 316 STILTS STL

$$emb = \text{min. Eff. Embedment} = 3 \ 1/2 \ \text{in.}$$



$$ed = \text{min. edge distance} = 5 \ \text{in.}$$

$$ct = \text{concrete thickness} = 6 \ \text{in.}$$

$$f_c = \text{Concrete strength} = 4000 \ \text{psi NORMAL Weight Concrete}$$

$$T_{cap} = \text{Tension capacity} = 4577 \ \text{lbs. LRFD}$$

$$V_{cap} = \text{Shear capacity} = 2869 \ \text{lbs. LRFD}$$



CHECK ANCHORAGE:


$$\left(\frac{0 \ \text{lbs.}}{4577 \ \text{lbs.}} \right)^{5/3} + \left(\frac{1797 \ \text{lbs.}}{2869 \ \text{lbs.}} \right)^{5/3} = 0.46 < 1.0$$

must be less than 1.0 PASS



Specifier's comments:


1 Input data



Anchor type and diameter:	HIT-RE 500 V3 + HAS-R 304/316 SS 7/8
Item number:	2045013 HAS-R 316 SS 7/8"x10" (element) / 2123401 HIT-RE 500 V3 (adhesive)
Effective embedment depth:	$h_{ef,opti} = 3.500$ in. ($h_{ef,limit} = 4.000$ in.)
Material:	ASTM F 593
Evaluation Service Report:	ESR-3814
Issued Valid:	1/1/2023 1/1/2025
Proof:	Design Method ACI 318-14 / Chem
Stand-off installation:	$e_b = 0.000$ in. (no stand-off); $t = 0.250$ in.
Anchor plate ^R :	$l_x \times l_y \times t = 4.000$ in. x 4.000 in. x 0.250 in.; (Recommended plate thickness: not calculated)
Profile:	no profile
Base material:	cracked concrete, 4000, $f'_c = 4,000$ psi; $h = 6.000$ in., Temp. short/long: 32/110 °F
Installation:	hammer drilled hole, Installation condition: Dry
Reinforcement:	tension: condition B, shear: condition B; no supplemental splitting reinforcement present edge reinforcement: none or < No. 4 bar
Seismic loads (cat. C, D, E, or F)	Tension load: yes (17.2.3.4.3 (d)) Shear load: yes (17.2.3.5.3 (c))

^R - The anchor calculation is based on a rigid anchor plate assumption.

Geometry [in.] & Loading [lb, in.lb]





www.hilti.com

Company:		Page:	3
Address:		Specifier:	
Phone Fax:		E-Mail:	
Design:	Concrete -STNDRD	Date:	4/27/2023
Fastening point:			

2 Proof I Utilization (Governing Cases)

Loading	Proof	Design values [lb]		Utilization	Status
		Load	Capacity	β_N / β_V [%]	
Tension	Sustained Tension Load Bond Strength	1	4,577	1 / -	OK
Shear	Concrete edge failure in direction x+	1,797	2,869	- / 63	OK

Loading	β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
Combined tension and shear loads	0.000	0.626	5/3	46	OK

3 Warnings

- Please consider all details and hints/warnings given in the detailed report!

Fastening meets the design criteria!